



| SCHEDULE OF ITEMS | | | |
|-------------------|--|----------|--|
| ITEM NO. | DESCRIPTION | ITEM NO. | DESCRIPTION |
| 1 & 2 | REFER TO DRAWING 17 | 8 | RESILIENT SEATED BALL VALVE |
| 3 | ALL POLYETHYLENE PIPE & FITTINGS MUST BE WATERMARK APPROVED PIPE TO BE PN12.5 MINIMUM | 9 | APPROVED LINE STRAINER |
| 4 | POLYETHYLENE TO COPPER CONNECTOR | 10 | APPROVED HIGH HAZARD TESTABLE BACKFLOW PREVENTION DEVICE |
| 5 | DEPTH - MINIMUM COVER AUST. STANDARD AS/NZS 3500.1 (CLAUSE 5.10 & 5.11) AND LOCAL COUNCIL REQUIREMENTS | 11 | ELBOW |
| 6 | 20mm / 25mm RIGHT ANGLE BALL VALVE | 12 | TIMBER STAKE |
| 7 | 20mm / 25mm APPROVED WATER CORPORATION SUPPLIED WATER METER | 13 | HOSE BIB TAP |
| | | 14 | HOSE CONNECTION VACUUM BREAKER |
| | | 15 | TUBE BUSH |
| | | 16 | BRASS PLUG |

SEE GENERAL NOTES FOR FURTHER INFORMATION

| STANDARD LEGEND | | |
|-----------------|------------|---|
| ⊗ | V | Valve |
| ○ | M | Meter |
| □ | D.B. | Dirt Box |
| — | S.P. | Straight Piece |
| ⊥ | T.F. | Testing Ferrule |
| ▭ | L.S. | Line Strainer |
| ⌌ | B.P.D. | Backflow Prevention Device (Testable or Non-Testable) |
| ⌌ | S.C.V.T | Single Check Valve Testable |
| ⌌ | S.C.D.A.T. | Single Check Detector Assembly Testable |