



PROPERTY OWNER'S RESPONSIBILITY FROM WATER MAIN EXCEPT FOR WATER METER

| SCHEDULE OF ITEMS | | | |
|---|--|---|---|
| ITEM NO. | DESCRIPTION | ITEM NO. | DESCRIPTION |
| 1 & 2 | REFER TO DRAWING 17 | 9 | RESILIENT SEATED ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE |
| 3 | ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE | 10 | STRAINER TO CONFORM TO BACKFLOW PREVENTION DEVICE MANUFACTURER'S REQUIREMENTS |
| 4 | DIRT BOX WATER CORPORATION SUPPLIED | | |
| 5 | SPACER 5 x PIPE DIAMETER | 11 | HIGH / MEDIUM TESTABLE BACKFLOW PREVENTION DEVICE NOTE: MIN HEIGHT 300mm TO DISCHARGE PORT |
| 6 | APPROVED WATER CORPORATION SUPPLIED WATER METER | | |
| 7 | SPACER 3 x PIPE DIAMETER | | |
| 8 | TESTING FERRULE (OUTLET CAPPED) MINIMUM 20mm | METERS 50mm AND ABOVE TO BE INDEPENDENTLY SUPPORTED FROM PIPE WORK | |
| SEE GENERAL NOTES FOR FURTHER INFORMATION | | | |

| STANDARD LEGEND | |
|-----------------|--|
| | V Valve |
| | M Meter |
| | D.B. Dirt Box |
| | S.P. Straight Piece |
| | T.F. Testing Ferrule |
| | L.S. Line Strainer |
| | B.P.D. Backflow Prevention Device (Testable or Non-Testable) |
| | S.C.V.T Single Check Valve Testable |
| | S.C.D.A.T. Single Check Detector Assembly Testable |