










SCHEDULE OF ITEMS	
ITEM NO.	DESCRIPTION
1 & 2	REFER TO DRAWING 17
3	ISOLATING VALVE. IF BUTTERFLY VALVE TO BE GEAR SHUT TYPE (RESILIENT SEATED)
4	SINGLE CHECK DETECTOR ASSEMBLY TESTABLE. VALVE TO CONFORM TO AS/NZS2845
5	25mm BYPASS METER SUPPLIED BY WATER CORPORATION.
6	25mm DUAL SPRING LOADED CHECK VALVE
7	LOCKABLE BALL VALVES WITH A003 KEYED LOCKS
8	TEST PORT
SEE GENERAL NOTES FOR FURTHER INFORMATION	

STANDARD LEGEND	
	V Valve
	M Meter
	D.B. Dirt Box
	S.P. Straight Piece
	T.F. Testing Ferrule
	L.S. Line Strainer
	B.P.D. Backflow Prevention Device (Testable or Non-Testable)
	S.C.V.T. Single Check Valve Testable
	Single Check Detector Assembly Testable